


Number : C-20-1500-R3  
Participant : YESPAN ELEKTRİK SAN. TİC. LTD. ŞTİ.  
Manufacturer : YESPAN ELEKTRİK SAN. TİC. LTD. ŞTİ.  
Definition of Product : H TYPE IP55 – IK10 EMPTY ENCLOSURE  
S TYPE PLAIN DOOR IP55 – IK10 EMPTY ENCLOSURE  
S TYPE GLASS DOOR IP55 – IK08 EMPTY ENCLOSURE  
S TYPE GLASS DOOR – CEILING VENTED EMPTY  
ENCLOSURE IP42-İK08/İK10  
Technical Data (Rated Values) : IK10 (ENCLOSURE), IK08 (GLASS DOOR), IP55 (S&H TYPE), IP42 (S TYPE GLASS DOOR)  
Test Standard : IEC 62208:2011  
Subject : TEST RESULT (PASSED)  
Applied Tests : Static Load  
Lifting  
Axial Loads of Metal Inserts  
Degree of Protection Against External Mechanical Impacts (IK10&İK08)  
Resistance to abnormal Heat and to Fire  
Continuity of the Protective Circuit  
Resistance to Corrosion (Severity Test B)  
Resistance to Ultra-Violet (UV) Radiation  
Thermal Power Dissipation Capability  
Degree of Protection (IP55 & IP42)  
Test Report Number : 20-1500-R3-N1-1  
Date of Report : 10.07.2020  
Date of Certificate : 05.01.2021

Person in Charge of Test

Head of Testing Laboratory

Cem AKDOĞAN

Cahit GÖKSEL



Sertifika detaylarını karekod ile kontrol edebilirsiniz.  
You can check the certificate details via QR code.

[www.lvt.com.tr](http://www.lvt.com.tr)