



TÜRK STANDARDLARI ENSTİTÜSÜ
TÜRK STANDARDLARINA UYGUNLUK BELGESİ
TURKISH STANDARDS INSTITUTION
CERTIFICATE OF CONFORMITY TO TURKISH STANDARDS

Markanın Tanımı Description of the Mark
TSE veya/or  veya/or T S E

BELGE NUMARASI 026216-TSE-01/03
REFERENCE NUMBER OF LICENCE

BELGENİN İLK VERİLİŞ TARİHİ 04.02.2010
DATE OF FIRST ISSUE OF LICENCE

BELGENİN SON GEÇERLİLİK TARİHİ 31.12.2024
LICENCE VALID UNTIL

BELGE SAHİBİ KURULUŞUN ADI YILDIRIM ELSAN ELEKTİRİK İNŞAAT TAAHHÜT
NAME OF THE LICENCE HOLDER MÜHENDİSLİK HİZMETLERİ SANAYİ TİCARET LİMİTED
ŞİRKETİ

BELGE SAHİBİ KURULUŞUN ADRESİ AYDIN ORGANİZE SANAYİ BÖLGESİ 2.CADDE NO:41 UMURLU
ADDRESS OF THE LICENCE HOLDER MERKEZ AYDIN/TÜRKİYE

ÜRETİM YERİ ADI YILDIRIM ELSAN ELEKTİRİK İNŞAAT TAAHHÜT MÜHENDİSLİK
NAME OF THE MANUFACTURING PLACE HİZMETLERİ SANAYİ TİCARET LİMİTED ŞİRKETİ

ÜRETİM YERİ ADRESİ AYDIN ORGANİZE SANAYİ BÖLGESİ 2.CADDE NO:41 UMURLU
ADDRESS OF THE MANUFACTURING PLACE MERKEZ AYDIN / TÜRKİYE

İPTAL EDİLEN BELGE NUMARASI (Varsa) 026216-TSE-01/02
INDICATION OF SUPERSEDED LICENCE (if any)

TESCİLLİ TİCARİ MARKASI yespan
REGISTERED TRADE MARK

İLGİLİ TÜRK STANDARDI TS EN 61439-2 / 09.10.2013 -- TS EN 61439-1 / 09.10.2013
RELATED TURKISH STANDARD

BELGE KAPSAMI
SCOPE OF LICENCE



TYPE: 4000 A WITH INCOMING CIRCUIT BREAKER LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES

EXTERNAL DESIGN OF ASSEMBLIES: WITH ENCLOSURE
CONDITIONS OF INSTALLATION OF ASSEMBLIES: ASSEMBLY FOR INDOOR INSTALLATION
ACCESS TO MANUALLY OPERATED DEVICES: AUTHORIZED PERSONS
TYPE OF COOLING: FORCED COOLING

RATED VOLTAGE(Un): 400V
RATED OPERATIONAL VOLTAGE(Ue): 400 V
RATED IMPULSE WITHSTAND VOLTAGE(Uimp): 8 kV
IMPULSE WITHSTAND VOLTAGES OF AUXILIARY CIRCUITS(Uimp): -



e-imzalı/e-signed

28.02.2024

On Behalf Of The Head Of Certification Center
Ahmet NAMLI

Izmir Certification Manager

*This certificate also shows that the production place of the certified product meets the requirements of Institute.
*This certificate under any circumstances cannot be changed, duplicated partially or in a way that makes it difficult to read and erasure cannot be done.
*TSE * Address: 8780/1 sokak No:5 Çiğli / İZMİR * Telephone: 0232 376 24 25(3H) * Fax: 0 232 445 42 32
*TSE HEAD OF CERTIFICATION CENTER; Address: Necatibey Cad. No:112 06100 Bakanlıklar/ANKARA – Telephone: 0 312 416 64 81 / 416 64 27, Fax:0 312 416 66 17 E-mail : bmb@tse.org.tr , web : www.tse.org.tr



Please check the accuracy and validity of the certificate from <https://evrakkontrol.tse.org.tr/BelgeDogrulama.aspx?p=9raayp3m>

1 / 5